

Test Monitoring Center

https://www.astmtmc.org

ASTM D02.B0.07 Semi-Annual Report Bench Test Monitoring

D6417, D5133 (GI), D5800, D6335 (TEOST), D7097(MTEOS), D6082, D874 and D7528 (ROBO)

October 2022

Table of Contents

Section	Topic
Executive Summary	
	Summary Items
	Calibrated Labs and Stands
Test Area Status Summaries	
	<u>D6417</u>
	<u>D5800</u>
	<u>D5133</u>
	<u>D6335</u>



Table of Contents

Section	Topic
Test Area Status Summaries	(cont.)
	<u>D7097</u>
	<u>D6082</u>
	<u>D874</u>
	<u>D7528</u>
Additional Information	
	Reference Oil Inventories
	Additional Information



B0.07 Bench Testing Executive Summary

- ▶ D5133 (Gelation Index)
- Zero operationally invalid tests this period compared to 17 tests in the previous period.
- ▶ D6335 (TEOST)
- TMC Memorandum 21-044, updating targets for reference oil 75-1 was issued 11/3/2021
- Fail rate for TEOST doubled with respect to previous six-month period.



B0.07 Bench Testing Executive Summary

- D6082 (High Temperature Foam) and D874 (Sulfated Ash)
- For the second consecutive 6-month period, there were no tests which failed to meet acceptance criteria for both these test types.
- ▶ D7528 (ROBO)
- Long term (very linear) mild severity trend, as evidenced in the Cusum plot, may indicate that targets may not be correct.
- Information letter 21-01, allowing an option to use dilute nitrogen dioxide in air was issued 11/3/21
- ▶ D5800 (NOACK)
- Slight leveling of CUSUM slope this period. Long-term severity trend (severe) in the CUSUM plots was a topic of discussion at the Surveillance Panel meeting in October. The panel decided that a target change wasn't appropriate and that the severe trend abating may be due to more D procedure rigs as well as a difference in lab/rig make up.





Calibrated Labs and Stands*

(change shown in parentheses)

Test	Labs	Stands
D6417	7 (0)	9 (0)
D5800	10 (+1)	25 (+4)
D5133 (GI)	8 (+3)	49 (+4)
D6335 (TEOST)	8 (0)	13 (+1)
D7097 (MTEOS)	8 (0)	40 (+3)
D6082	6 (+2)	7 (+2)
D874	4 (+1)	
D7528 (ROBO)	7 (+1)	9 (-18)

*As of 9/30/2022

TABLE of CONTENTS



D02.B0.07 TMC Monitored Tests



ASTM D 6417

April 1, 2022 - September 30, 2022



Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	18
Failed Calibration Test	OC	1
Total		19

Number of Labs Reporting Data: 7
Fail Rate of Operationally Valid Tests: 5%



Statistically Unacceptable Tests (OC)	No. Of Tests
Volatility Loss Mild	1
Volatility Loss Severe	0

- There were no operationally invalid tests reported this period
- No D6417 TMC technical updates were issued this report period.



Period Precision and Severity Estimates


Area % Volatized @ 371°C	n	df	Pooled s	Mean Δ/s
Initial Selected Oils from RR	54	51	0.39	
10/1/19 through 3/31/20	17	14	0.30	0.09
4/1/20 through 9/30/20* 4/1/20 through 9/30/20* 10/1/20 through 3/31/21*	16 14 21	13 11 18	0.41 0.31 0.47	-0.34 0.01 -0.81
10/1/20 through 3/31/21*	19	16	0.37	-0.43
4/1/21 through 9/30/21	17	14	0.39	-0.28
10/1/21 through 3/31/22	20	17	0.51	0.13
4/1/22 through 9/30/22	19	16	0.48	-0.67

^{*}Period statistics with two mild results from rigs D5/D6 included and excluded (operational problem suspected but lab never confirmed)



D6417 Precision Estimates


Area % Volatized @ 371°C Pooled s





D6417 Severity Estimates


Area % Volatized @ 371°C Mean Δ/s





D6417 Lab Severity Estimates

Area % Volatized @ 371°C Mean Δ/s






- Precision (Pooled s) has slightly improved this period relative to previous period and historical rates.
- Performance (Mean Δ/s) has fallen to -0.67 s, mild and further from target compared to prior reporting period.
- CUSUM severity plot trending mild.






SAMPLE AREA % VOLATIZED

CUSUM Severity Analysis



D6417 Performance by Oil


Area % Volatized @ 371°C Mean





D6417 Performance by Oil


Area % Volatized @ 371°C Standard Deviation





D6417 Performance by Oil

Area % Volatized @ 371°C Mean Δ/s







D02.B0.07 TMC Monitored Tests



ASTM D 5800

April 1, 2022 - September 30, 2022



D5800: Evaporation Loss of Lubricating Oil by Noack Method

Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	132
Failed Calibration Test	OC	4
Operationally Invalidated by Lab	LC	2
Total		138

Number of Labs Reporting Data: 9
Fail Rate of Operationally Valid Tests: 3%



D5800: Evaporation Loss of Lubricating Oil by Noack Method

Statistically Unacceptable Tests (OC)	No. Of Tests
Ei Level 3 Alarm Mild	3
Ei Level 3 Alarm Severe	0
Zi Level 2 Severity Alarm Mild	1

- The 4 OC tests were on four different rigs at 4 labs...
- No operationally valid tests exceed ±3 s this period.



D5800: Evaporation Loss of Lubricating Oil by Noack Method

- Two operationally invalid calibration runs were reported this period:
 - One test was invalid due to failed QC result performed on the day of calibration (LC)
 - •One test where the test sample was run at an incorrect temperature. (LC)
- No D5800 technical memos were issued by the TMC this period.



D5800: Evaporation Loss of Lubricating Oil by Noack Method

Period Precision and Severity Estimates

Sample Evaporation Loss, mass %	n	df	Pooled s	Mean ∆/s
Targets Effective 02/07/201	78	75	0.0465	
4/1/19 through 9/30/19	164	161	0.81	0.65
10/1/19 through 3/31/20 ¹	146	143	0.0503	0.54
4/1/20 through 9/30/20 ¹	136	133	0.0659	0.35
10/1/20 through 3/31/21 ¹	140	137	0.0495	0.53
4/1/21 through 9/30/21 ¹	136	133	0.0510	0.45
10/1/21 through 3/31/22	139	136	0.0463	0.24
4/1/22 through 9/30/22	135	133	0.0469	-0.10

¹Began monitoring natural log transformed test results on 20200207 making logarithmic scale changes for target and period precision estimates starting April 2020 report period.



D5800: Evaporation Loss of Lubricating Oil by Noack Method

Performance Comparison by Procedure & Model Sample Evaporation Loss, Mass %

Procedure	n	df	Pooled s	Mean ∆/s
Procedure B	82	79	0.0414	0.17
Procedure C	N	o Procedure C tests	reported this perio	d.
Procedure D	54	51	0.0411	-0.50
Model	n	df	Pooled s	Mean ∆/s
NCK2	5	2	0.0085	0.26
NCK25G	77	74	0.0424	0.16


1 Procedure B NCK2 Rig

15 Procedure B NCK25G Rigs

9 Procedure D NS2 Rigs



D5800 Precision Estimates




^{*}Began monitoring natural log transformed test results on 20200207 making logarithmic scale changes for target and period precision estimates starting April 2020 report period.



D5800 Severity Estimates


Sample Evaporation Loss, mass % Mean Δ/s





D5800 Lab Severity Estimates

Sample Evaporation Loss, mass % Mean Δ/s





D5800: Evaporation Loss of Lubricating Oil by Noack Method

- Precision (Pooled s) is comparable to target precision (in natural log transformed units).
 - Compares well to prior periods
- ▶ Performance (Mean Δ /s) is -0.10 s mild.
 - Procedure B rigs are trending 0.17 s severe while Procedure D rigs are trending -0.50 s mild.
- Procedure D tests have been trending mild for the past few periods while the long-term severe trend with Procedure B tests has lessened. The industry EWMA Control chart is currently in control.





EVAPORATION LOSS, MASS%






D5800 VOLATILITY BY NOACK INDUSTRY OPERATIONALLY VALID DATA




EVAPORATION LOSS, MASS%




D5800 VOLATILITY BY NOACK INDUSTRY OPERATIONALLY VALID DATA



EVAPORATION LOSS, MASS%




D5800 VOLATILITY BY NOACK INDUSTRY OPERATIONALLY VALID DATA Procedure B EVAPORATION LOSS, MASS%



D5800 VOLATILITY BY NOACK INDUSTRY OPERATIONALLY VALID DATA


Procedure D results only EVAPORATION LOSS, MASS%





D5800 Performance by Oil

Sample Evaporation Loss, mass %




Target* APR '21* OCT '21* APR '22* OCT '22*

*Results transformed to natural log per updated LTMS 20200207



D5800 Performance by Oil

Sample Evaporation Loss, mass %




Target* APR '21* OCT '21 APR '22* OCT '22*

*Results transformed to natural log per updated LTMS 20200207



D5800 Performance by Oil

Sample Evaporation Loss, mass % Mean Δ/s







D02.B0.07 TMC Monitored Tests



ASTM D 5133

April 1, 2022 - September 30, 2022



Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	53
Failed Calibration Test	OC	4
Operationally Invalidated by Lab	LC, LS, XC, XS	0
Operationally Invalidated After Initially Reported as Valid	RC/RS	0
Acceptable Discrimination Tests	AS	1
Failed Discrimination Tests	OS	0
Total		58

Number of Labs Reporting Data: 9 (only 8 labs with chartable results this period) Fail Rate of Operationally Valid Calibration Tests: 6.9% Fail Rate of Operationally Valid Discrimination Tests: 0%



Statistically Unacceptable Calibration Tests (OC)	No. Of Tests
Gelation Index Mild	1
Gelation Index Severe	3

- Of the 4 OC tests:
 - One was -4.5455 s from target
 - One between +3-4 s from targets
 - One between +4-5 s from targets
 - One greater than +5 s from targets (5.1471)



Tests Excluded From Statistics (Operationally or Otherwise)	Validity Code	No. Tests
Total		0*

*There were no invalid tests this report period compared to 17 invalidated tests last period.



Period Precision and Severity Estimates


Gelation Index	n	df	Pooled s	Mean ∆/s
Targets Updated 202010011	34	32	1.44	
10/1/18 through 3/31/19	27	24	1.65	0.13
4/1/19 through 9/30/19	47	44	1.40	-0.25
10/1/19 through 3/31/20	41	37	2.45	-0.24
4/1/20 through 9/30/20	52	48	2.23	-0.11
10/1/20 through 3/31/21 ²	116	113	3.74	-0.86
4/1/21 through 9/30/21	75	73	1.71	-0.20
10/1/21 through 3/31/22	61	59	1.55	-0.84
4/1/22 through 9/30/22	57	55	1.28	-0.41

¹Target precision updated to current reference oils GIA17 and 1009 only ²Changed from bath to head-based monitoring scheme 10/1/20



D5133 Precision Estimates

Gelation Index Pooled s




*Changed from bath to head-based monitoring scheme



D5133 Severity Estimates

Gelation Index Mean ∆/s




*Changed from bath to head-based monitoring scheme



D5133 Lab Severity Estimates

Gelation Index Mean ∆/s





- Fail rate of operationally valid tests is 6.9% this period
 - Compared to 12.3% fail rate last period
 - There were no reported fails on operationally valid discrimination runs
 - Historic period fail rates have ranged between 6% and 26%
- Precision (Pooled s) is slightly more precise than last period
 - Comparable to updated target precision
- ▶ Performance (Mean Δ /s) is -0.41 s mild but closer to target
 - Six of Eight labs reporting mild of target
- A round robin was completed to evaluate a calibration oil that performs closer to the GF-5/6 pass/fail limit of 12 GI
 - GIC18 was voted into rotation by the Surveillance Panel
 - Replaces oil 58 that was reclassified as a discrimination oil




V la tio Ф

D5133 GELATION INDEX INDUSTRY OPERATIONALLY VALID DATA



GELATION INDEX


CUSUM Severity Analysis



D5133 GELATION INDEX INDUSTRY OPERATIONALLY VALID DATA








21NOV22:15:54

D5133 Performance by Oil

Gelation Index








D5133 Performance by Oil

Gelation Index





D5133 Performance by Oil

Gelation Index Mean ∆/s




TABLE of CONTENTS



D02.B0.07 TMC Monitored Tests



ASTM D 6335

April 1, 2022 - September 30, 2022



Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	25
Failed Calibration Test	OC	4
Operationally Invalidated by Lab	LC, XC	0
Total		29

Number of Labs Reporting Data: 8

Fail Rate of Operationally Valid Tests: 13.8%



Statistically Unacceptable Tests (OC)	No. Of Tests
Total Deposits Severe	4

- The four statistically unacceptable results this period were multiple fails on two stands (stands D3 and G4; all four results severe of target).
- There were no operationally invalid tests reported this period.
- TMC Memo 21–044 issued November 3, 2021, updating targets for reference oil 75–1.



Period Precision and Severity Estimates

Total Deposits, mg	n	df	Pooled s	Mean ∆/s
Updated Targets 202010011	46	44	4.85	
4/1/17 through 9/30/19 ² 4/1/17 through 9/30/19 ²	30 26	28 24	12.66 7.35	0.47 -0.23
10/1/19 through 3/31/20	32	30	6.08	0.28
4/1/20 through 9/30/20 ³ 4/1/20 through 9/30/20 ³	33 26	30 23	11.44 10.10	0.02 -0.02
10/1/20 through 3/31/21	26	23	8.39	0.42
4/1/21 through 9/30/21	31	28	8.27	-0.36
10/1/21 through 3/31/22	27	25	6.22	0.55
4/1/22 through 9/30/22	29	27	10.32	0.80

¹Target precision updated to include only current oils 75–1 and 435–2


³Rig with six OC results included and excluded.



²Four consecutive OC results on same rig included and excluded.

D6335 Precision Estimates


Total Deposits, mg Pooled s





D6335 Severity Estimates


Total Deposits, mg





D6335 Lab Severity Estimates

Total deposits, mg Mean Δ/s





- Precision (Pooled s) is poorer when compared to the previous period and is larger (more imprecise) compared to all historical rates going back 3.5 years (to APR '19)
 - Less precise than target precision
 - > There were no tests reported using oil 75
- > Performance (Mean Δ/s) is 0.80 s severe this period (compared to 0.55 s severe last period)
- > Period fail rate of 13.8% on tests reported as operationally valid
 - ➤ Fail rate has almost doubled (13.8% vs 7.0%) when compared to previous six-month report period.
 - All on Rod Batch N
 - > Two Units had all four fails
- > All tests this period report using Rod Batch M or N.




TEOST -33C INDUSTRY OPERATIONALLY VALID DATA



TOTAL DEPOSITS MG


CUSUM Severity Analysis



TEOST -33C INDUSTRY OPERATIONALLY VALID DATA




TOTAL DEPOSITS MG



D6335 Performance by Oil

Total Deposits, mg Mean








D6335 Performance by Oil


Total Deposits, mg





D6335 Performance by Oil

Total Deposits, mg $Mean \Delta/s$







D02.B0.07 TMC Monitored Tests



ASTM D 7097

April 1, 2022 - September 30, 2022



D7097: Deposits by MHT TEOST

Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	66
Failed Calibration Test	OC	11
Operationally Invalidated by Lab	LC	3
Operationally Invalidated After Initially Reported as Valid	RC	0
Instrument Shakedown Run	NI	3
Total		83

Number of Labs Reporting Data: 8
Fail Rate of Operationally Valid Tests: 14%



D7097: Deposits by MHT TEOST

Statistically Unacceptable Tests (OC)	No. Of Tests
Total Deposits Mild	0
Total Deposits Severe	11



D7097: Deposits by MHT TEOST Summary of Invalid Tests

Operationally Invalid Tests	Validity Code	No. Of Tests
Catalyst Weight ratio incorrect	LC	3



D7097: Deposits by MHT TEOST

Period Precision and Severity Estimates


Total Deposits, mg	n	df	Pooled s	Mean ∆/s
Current Targets 9/30/2021 ¹	38	36	4.94	
10/1/18 through 3/31/19	97	95	5.86	-0.14
4/1/19 through 9/30/19	109	107	6.40	-0.30
10/1/19 through 3/31/20	103	101	7.02	-0.02
4/1/20 through 9/30/20	72	70	4.87	-0.22
10/1/20 through 3/31/21	101	99	8.40	0.17
4/1/21 through 9/30/21	81	78	7.25	-0.02
10/1/21 through 3/31/22	75	73	8.86	0.18
4/1/22 through 9/30/22	77	75	7.69	0.69

¹Target precision updated to reference oils 432 and 434–3 preliminary



D7097 Precision Estimates

Total Deposits, mg Pooled s




*Target precision updated to reference oils 432 and 434-3 preliminary



D7097 Severity Estimates

Total Deposits, mg

Mean ∆/s




*One severe OC test from instrument G5 excluded (8.9 s)



D7097 Lab Severity Estimates


Total Deposits, mg $Mean \Delta/s$





D7097: Deposits by MHT TEOST

Total Deposits, mg Mean Δ/s Severity by CATBATCH and Period






D7097: Deposits by MHT TEOST


- Precision (Pooled s) remains high, but did move closer to target in this reporting period
 - Very nearly matching precision from one year ago
- Performance (Mean Δ/s) has moved significantly more severe (+0.69 s)
- All operationally valid tests this period report using Rod Batches M or N (new).
- All operationally valid calibration tests this period report using Catalyst Batch 1 19BA (n=7) 19BA-1 (n=2) or 20AB (n=74)



D7097: Deposits by MHT TEOST

- Overall severity on catalyst batch 19BA (n=344) appears to be on target for oils 432, 434 and 434-3 (Yi = -0.04).
- Overall severity on catalyst batch 20AB (n=95) appears to be slightly severe of target for oils 432, 434 and 434-3 (Yi = 0.65)








MHT -4 TEOST INDUSTRY OPERATIONALLY VALID DATA



TOTAL DEPOSITS MG


CUSUM Severity Analysis



MHT -4 TEOST INDUSTRY OPERATIONALLY VALID DATA




TOTAL DEPOSITS MG



MHT -4 TEOST INDUSTRY OPERATIONALLY VALID DATA




TOTAL DEPOSITS MG



COUNT IN COMPLETION DATE ORDER

D7097 Performance by Oil

Total Deposits, mg Mean






D7097: Deposits by MHT TEOST

Total Deposits, mg








D7097: Deposits by MHT TEOST

Total Deposits, mg Mean Δ/s





D02.B0.07 TMC Monitored Tests



ASTM D 6082

April 1, 2022 - September 30, 2022



Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	15
Acceptable Discrimination Test	AS	7
Operationally Invalid, Reported as Valid	RC	1
Total		23

Number of Labs Reporting Data: 6

Fail Rate of Operationally Valid Calibration Tests: 0%



Statistically Unacceptable Tests (OC, OS)	No. Of Tests
Foam Tendency Mild	0
Foam Tendency Severe	0

- All severe oil discrimination runs (on TMC oil 66) reported this period demonstrated acceptable discrimination.
 - Discrimination runs are not evaluated for overall period precision or severity due to poor test precision above 100 ml foam tendency.
- There was one operationally invalid result this report period.
- There were no statistically unacceptable results this report period.



Period Precision and Severity Estimates

Foam Tendency, ml	n	df	Pooled s	Mean ∆/s
Targets updated 202010011	18	17	9	
4/1/18 through 9/30/18	14	13	9	-0.07
10/1/18 through 3/31/19	14	13	12	-0.07
4/1/19 through 9/30/19	14	12	12	-0.18
10/1/19 through 3/31/20	15	13	10	-0.23
4/1/20 through 9/30/20	13	11	8	-0.85
10/1/20 through 3/31/21	12	10	7	-0.48
4/1/21 through 9/30/21	14	13	7	-0.48
10/1/21 through 3/31/22	13	12	7	-0.57
4/1/22 through 9/30/22	15	14	4	-0.52

¹Target precision updated to current reference oil FOAMB18




Period Precision and Severity Estimates

Foam Stability @ 1 min, ml	n	Mean	S
Current Targets	18	0.00	0.00
4/1/18 through 9/30/18	14	No non-zero d	occurrences
10/1/18 through 3/31/19	14	No non-zero d	occurrences
4/1/19 through 9/30/19	14	No non-zero d	occurrences
10/1/19 through 3/31/20	15	No non-zero d	occurrences
4/1/20 through 9/30/20	13	No non-zero d	occurrences
10/1/20 through 3/31/21	12	No non-zero d	occurrences
4/1/21 through 9/30/21	13	No non-zero d	occurrences
10/1/21 through 3/31/22	13	No non-zero d	occurrences
4/1/22 through 9/30/22	15	No non-zero d	occurrences




D6082 Performance by Oil

Foam Tendency, ml Mean






Foam Tendency, ml Pooled s






Foam Tendency, ml Mean ∆/s





Current Period Severity Estimates by Lab Foam Tendency, ml





- Foam Tendency Precision (Pooled s) is the same as last period
 - More precise than oil FOAMB18 target precision
 - Oil 1007 has been completely consumed. Third consecutive report period where all reference tests were conducted only on replacement oil FOAMB18.
- ▶ Performance (Mean Δ /s) is -0.52s mild
 - Three consistent periods of -0.5s mild performance with FOAMB18.
 - Target performance, set on 18 runs in a RR, may need revisited.
- No non-zero occurrences of Foam Stability
- All seven severe oil discrimination runs (on TMC oil 66) demonstrated acceptable discrimination on foam tendency (>100 ml).




D6082 HIGH TEMPERATURE FOAM INDUSTRY OPERATIONALLY VALID DA'



FOAM TENDENCY

CUSUM Severity Analysis



D6082 HIGH TEMPERATURE FOAM INDUSTRY OPERATIONALLY VALID DA' OIL FOAMB18 DATA ONLY

FOAM TENDENCY






TABLE of CONTENTS

D02.B0.07 TMC Monitored Tests



ASTM D 874

April 1, 2022 - September 30, 2022



Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	8
Total		8

Number of Labs Reporting Data: 4
Fail Rate of Operationally Valid Tests: 0%



Statistically Unacceptable Tests (OC)	No. Of Tests
No Failed tests	0

• No operationally invalid or statistically unacceptable tests this report period.




Period Precision and Severity Estimates

Total Deposits, mg	n	df	Pooled s	Mean Δ/s
Current Targets	81	78	0.07	
4/1/18 through 9/30/18	8	5	0.04	-0.22
10/1/18 through 3/31/19	8	5	0.04	-0.33
4/1/19 through 9/30/19	8	5	0.04	-0.18
10/1/19 through 3/31/20	7	4	0.04	-0.71
4/1/20 through 9/30/20	8	5	0.03	-0.30
10/1/20 through 3/31/21	8	5	0.02	-0.35
4/1/21 through 9/30/21	10	7	0.15	0.37
10/1/21 through 3/31/22	9	6	0.05	-0.07
4/1/22 through 9/30/22	8	6	0.06	-0.38




Sulfated Ash, mass% Pooled s






Sulfated Ash, mass% Mean ∆/s





Sulfated Ash, mass% Mean ∆/s





- Precision (Pooled s) is almost identical with respect to the previous period and is in line with historical estimates
- ▶ Performance (Mean Δ /s) has regressed to -0.38 s




D874 INDUSTRY OPERATIONALLY VALID DATA




TEST SAMPLE PERCENT SULFATED ASH

CUSUM Severity Analysis




Sulfated Ash, mass% Mean





Sulfated Ash, mass%





Sulfated Ash, mass% Mean ∆/s




TABLE of CONTENTS



D02.B0.07 TMC Monitored Tests



ASTM D 7528

April 1, 2022 - September 30, 2022



D7528: Oxidation by ROBO

Test Status	Validity Code	No. Tests
Acceptable Calibration Test	AC	95
Failed Calibration Test	OC	10
Operationally Invalidated by Lab	LC, XC	5
Operationally Invalidated After Initially Reported as Valid	RC	2
Total		112

Number of Labs Reporting Data: 10 Fail Rate of Operationally Valid Tests: 11%



D7528: Oxidation by ROBO

Statistically Unacceptable Tests (OC)	No. Of Tests
Natural Log (MRV Viscosity) Mild	7
Natural Log (MRV Viscosity) Severe	3
Total	10

■ Information Letter 21–1 was issued 11/3/21 and added an option to use dilute nitrogen dioxide in air



D7528: Oxidation by ROBO

Operationally Invalid Calibration Tests

Test Status	Cause	#
Invalid	Yield stress >35kPa	4
Aborted	Vacuum Pump Failure	1
Aborted	Electric Supply Failure	1
Aborted	Lost Sample	1
Totals		7




Period Precision and Severity Estimates

Natural Log (MRV Viscosity)	n	df	Pooled s	Mean Δ/s
Targets Updated 202110211	80	77	0.1551	
10/1/18 through 3/31/19	100	96	0.2738	0.04
4/1/19 through 9/30/19	95	91	0.2492	-0.32
10/1/19 through 3/31/20	158	153	0.2723	-0.10
4/1/20 through 9/30/20	119	113	0.2264	-0.76
10/1/20 through 3/31/21	113	108	0.3188	-0.11
4/1/21 through 9/30/21	116	110	0.1992	-0.37
10/1/21 through 3/31/22	106	102	0.2103	-0.36
4/1/22 through 9/30/22	105	101	0.1868	-0.06

¹Updated targets to include latest primary reference oils 434–3, 435–1 and 436




Natural Log (MRV Viscosity)






Natural Log (MRV Viscosity) Mean Δ/s





Natural Log (MRV Viscosity) Mean Δ/s





- Precision (Pooled s) is comparable to recent report periods but directionally better when compared to target precision
- Severity (Mean Δ/s) is -0.06 s mild for this report period
- CUSUM severity plot shows long term mild trend of varying levels
- Two labs did not report any runs this period



ROBO TEST INDUSTRY OPERATIONALLY VALID DATA



AGED OIL MRV APPARENT VISCOSITY







ROBO TEST INDUSTRY OPERATIONALLY VALID DATA



AGED OIL MRV APPARENT VISCOSITY




Natural Log (MRV Viscosity) Mean



*Single Oil 434-2 Run Not Included in this Analysis



Natural Log (MRV Viscosity)




*Single Oil 434-2 Run Not Included in this Analysis



Natural Log (MRV Viscosity)

Mean Δ/s



*Single Oil 434-2 Run Not Included in this Analysis

TABLE of CONTENTS





As of 9/30/2022



D5800

Oil	Year Rec'd By TMC ^A	Tests	TMC Inventory, gallons	Gallons Shipped last 6 months
VOLC12	2013	D5800	24.6	2.2
VOLD12	2013	D5800	25.2	2.4
VOLE12	2013	D5800	22.8	2.1
VOLD18	2018	D5800QC	832	82

^AThe integrity of TMC reference oils is confirmed annually by analytical QC testing of chemical and physical properties.



D6417, GI

Oil	Year Rec'd By TMC ^A	Tests	TMC Inventory, gallons	Gallons Shipped last 6 months
52	1995	D6417	59.4	0.02
55	1995	D6417	65.9	0.03
58	1998	D6417, D6417QC, GI	111.3	0.2
GIA17	2017	GI	6.3	2.0
GIC18	2018	GI	9.2	0.6
1009	2002	GI	35.7	0.2

^A The integrity of TMC reference oils is confirmed annually by analytical QC testing of chemical and physical properties.



TEOST, MTEOS & ROBO

Oil	Year Rec'd By TMC ^A	Tests	TMC Inventory, gallons	Gallons Shipped last 6 months
432	1998	MTEOS	102.0	0.4
75-1	2016	TEOST	3.2	1.1
435-2 ^B	2010	TEOST	35.4	1.0
434-3 ^B	2017	ROBO/MTEOS	28.3	3.2
435-1	2008	ROBO	336.8	11.3
436 ⁸	2014	ROBO	39.9	1.2



AThe integrity of TMC reference oils is confirmed annually by analytical QC testing of chemical and physical properties.

^BMulti-test oil; estimated aliquot reserved for bench testing.

D6082 & D874

Oil	Year Rec'd By TMC ^A	Tests	TMC Inventory, gallons	Gallons Shipped last 6 months
FOAMB18	2018	D6082	79.3	3.0
66	2002	D6082	71.9	1.0
820-2	2001	D874	3.3	0.1
90	2005	D874/D874QC	6.9	4.8
91	2006	D874	3.10	0.1

^A The integrity of TMC reference oils is confirmed annually by analytical QC testing of chemical and physical properties.





Additional Information



Additional Information

- Available on the TMC's Website:
 - Lubricant Test Monitoring System (LTMS) Document
 - CUSUM Severity Plots
 - Reference Data, Period Statistics and Timelines
 - Information Letters and Technical Memos
 - Report Forms & Data Dictionaries
 - Online Store, and more...

www.astmtmc.org





