

# **Test Monitoring Center**

Carnegie Mellon University 6555 Penn Avenue, Pittsburgh, PA 15206, USA http://astmtmc.cmu.edu 412-365-1000


2009

MEMORANDUM:	09-066
DATE:	December 3, 2009
TO:	Leonard Orzech, Chairman, Ball Rust Test Surveillance Panel
FROM:	Michael T. Kasimirsky Michael J. Resimisky
SUBJECT:	BRT Testing from April 1, 2009 through September 30,

A total of 132 BRT tests were reported to the Test Monitoring Center during the period from April 1, 2009 through September 30, 2009. Following is a summary of testing activity this period.

	Reporting Data
Number of Labs	4

Tests reported this period were distributed as shown below:




### NUMBER OF TESTS REPORTED BY LAB AND REPORT PERIOD

### Test Distribution by Oil and Validity

	-					То	tals
		1006	81	82	82-1	Last Period	This Period
Accepted for Calibration	AC	30	61	24	0	102	115
Hardware Qualification Run	NI	0	0	0	4	0	4
Rejected Mild	OC	0	0	1	0	1	1
Rejected Severe	OC	0	0	1	0	0	1
Operationally Invalid (lab)	LC	3	5	2	0	1	10
Operationally Invalid (lab/TMC)	RC	0	0	0	0	0	0
Aborted Calibration	XC	0	1	0	0	1	1
Total		33	67	28	4	105	132

## OPERATIONALLY VALID TESTS MEETING ACCEPTANCE CRITERIA



The above chart shows the percentage of accepted operationally valid tests. Two tests, at different labs, failed to meet the acceptance criteria this period; one mild and one severe, both ran oil 82.

		1006			81			82			82-1			Total	
Lab	Lost	Starts	%	Lost	Starts	%	Lost	Starts	%	Lost	Starts	%	Lost	Starts	%
А	0	14	0	1	30	3	0	13	0	0	0	0	1	57	2
В	0	5	0	0	11	0	1	4	25	0	0	0	1	20	5
D	0	2	0	0	2	0	0	1	0	0	0	0	0	5	0
G	3	12	25	5	24	21	1	10	10	0	0	0	9	46	20
Total	3	33	9	5	67	7	1	28	4	0	0	0	11	128	9

Lost Tests per Start by Lab and Oil

Lost tests are those that were aborted or operationally invalid.

### Causes for Lost Tests

			Oil		Validity			Loss Rate			
Lab	Cause		1006	81	82	LC	RC	XC	Lost	Starts	%
А	Air Compressor Failure			•		•			1	57	2%
В	Acid Delivery Failure				•	•			1	20	5%
	Wrong Test Length   Stalled Acid Pump		•			•			1		2%
C			•			•			1	- 46	2%
G	Airflow Problem			•		•			5		11%
	Variance Too High			•	•	•		•	2		4%
		Lost	3	6	2	10	0	1			
		Starts	33	67	28	128	128	128	1		
		%	9%	9%	7%	8%	0%	0.8%			

Average $\Delta$ /s by Lab									
Lab	n	AGVYI							
А	56	0.356							
В	19	0.979							
D	5	1.491							
G	37	-0.177							
Industry	117	0.337							

A/a by I ab ٨

Individual test results can be found on the TMC Web Page at the following link:

ftp://ftp.astmtmc.cmu.edu/refdata/bench/brt/data/

#### CUSUM PLOT

#### BALL RUST TEST INDUSTRY OPERATIONALLY VALID DATA

**CUSUM Severity Analysis** 01 J PR 01 010CT01 01JAN02 01APR02 JUL08 00108 JAN09 Apro9 000100 JAN08 808 80 000 0100102 01APR03 ~ 011102 £07∢710 1034 Ò 01710 948 ۵ ∢ 0 0 0 0 0 0 0 862 -776 **Min** 690 noiti 604 -518 -432 -۵ 346 -Standard 260 -174 -88 -2 -84 -170 -1 \*\*\*\*\*\* Т Т 180 360 540 720 1800 1980 900 1080 1260 1440 1620 2160 2340 2520 2700 2880 3060 0


**REFERENCE AVERAGE GRAY VALUE** 

COUNT IN COMPLETION DATE ORDER

02DEC09:14:01

### POOLED S:

Pooled s for this period is 10.67. Shown below is a bar chart comparing the pooled s values for AGV over the last four report periods.



#### STATUS OF REFERENCE OIL SUPPLY:

At the end of this report period, the testing oil supply stood as outlined in the following table:

		@ TMC			
Oil	Samples @ Labs	Samples (30 mL)	Gallons		
1006	23	5000	40.0		
81	40	1675	13.4		
82	26	900	7.2		
82-1	8	1225	9.8		
Total	97	8800	70.4		

#### **INFORMATION LETTERS:**

No information letters were issued this period.

#### **SUMMARY**

c:

- Over the course of this report period, AGV severity as measured by cusum plotting continued the mild trend that has existed since the inception of the test.
- Precision as measured by pooled standard deviation is comparable to previous periods.

MTK/mtk/astm1009.doc/mem09-066.mtk.doc

F. M. Farber J. A. Clark BRT Surveillance Panel <u>ftp://ftp.astmtmc.cmu.edu/docs/bench/brt/semiannualreports/brt-10-2009.pdf</u>

Distribution: email