



# Test Monitoring Center

Carnegie Mellon University  
6555 Penn Avenue, Pittsburgh, PA 15206, USA


<http://astmtmc.cmu.edu>  
412-365-1000

MEMORANDUM: 10-054  
DATE: November 22, 2010  
TO: Leonard Orzech,  
Chairman, Ball Rust Test Surveillance Panel  
FROM: Michael T. Kasimirsky *Michael T. Kasimirsky*  
SUBJECT: BRT Testing from April 1, 2010 through September 30, 2010

A total of 161 BRT tests were reported to the Test Monitoring Center during the period from April 1, 2010 through September 30, 2010. Following is a summary of testing activity this period.

|                | Reporting Data |
|----------------|----------------|
| Number of Labs | 4              |


Tests reported this period were distributed as shown below:



**Test Distribution by Oil and Validity**

|                                 |    | 1006      | 81        | 82        | Totals      |             |
|---------------------------------|----|-----------|-----------|-----------|-------------|-------------|
|                                 |    |           |           |           | This Period | Last Period |
| Accepted for Calibration        | AC | 48        | 65        | 40        | 153         | 110         |
| Hardware Qualification Run      | NI | 0         | 0         | 0         | 0           | 0           |
| Unacceptable for Calibration    | OC | 0         | 0         | 0         | 0           | 4           |
| Operationally Invalid (lab)     | LC | 1         | 2         | 1         | 4           | 3           |
| Operationally Invalid (lab/TMC) | RC | 0         | 0         | 1         | 1           | 0           |
| Aborted Calibration             | XC | 1         | 1         | 1         | 3           | 1           |
| <b>Total</b>                    |    | <b>50</b> | <b>68</b> | <b>43</b> | <b>161</b>  | <b>118</b>  |

**OPERATIONALLY VALID TESTS  
MEETING ACCEPTANCE CRITERIA**



The above chart shows the percentage of accepted operationally valid tests. No tests failed to meet the acceptance criteria this period.

Lost Tests per Start by Lab and Oil

| Lab   | 1006 |        |   | 81   |        |    | 82   |        |     | Total    |        |    |
|-------|------|--------|---|------|--------|----|------|--------|-----|----------|--------|----|
|       | Lost | Starts | % | Lost | Starts | %  | Lost | Starts | %   | Los<br>t | Starts | %  |
| A     | 0    | 21     | 0 | 0    | 26     | 0  | 1    | 20     | 5   | 1        | 67     | 1  |
| B     | 1    | 11     | 9 | 2    | 16     | 13 | 1    | 11     | 9   | 4        | 38     | 11 |
| D     | 0    | 3      | 0 | 0    | 4      | 0  | 1    | 1      | 100 | 1        | 8      | 13 |
| G     | 1    | 15     | 7 | 1    | 22     | 5  | 0    | 11     | 0   | 2        | 48     | 4  |
| Total | 2    | 50     | 4 | 3    | 68     | 4  | 3    | 43     | 7   | 8        | 161    | 5  |

Lost tests are those that were aborted or operationally invalid.

Causes for Lost Tests

| Lab | Cause                         | Oil  |    |    | Validity |     |     | Loss Rate |        |    |
|-----|-------------------------------|------|----|----|----------|-----|-----|-----------|--------|----|
|     |                               | 1006 | 81 | 82 | LC       | RC  | XC  | Lost      | Starts | %  |
| A   | Incorrect Test Length         |      |    | ●  | ●        |     |     | 1         | 67     | 1  |
| B   | Incorrect Test Length         |      | ●  |    | ●        |     |     | 1         | 38     | 3  |
|     | Incorrect Temperature         |      | ●  |    | ●        |     |     | 1         |        | 3  |
|     | Shaker Table Failure          | ●    |    | ●  |          |     | ●   | 2         |        | 5  |
| D   | Incorrect Machine Calibration |      |    |    |          | ●   |     | 1         | 8      | 13 |
| G   | Power Failure                 | ●    | ●  |    | ●        |     | ●   | 2         | 48     | 4  |
|     | Lost                          | 2    | 3  | 2  | 4        | 1   | 3   |           |        |    |
|     | Starts                        | 50   | 68 | 43 | 161      | 161 | 161 |           |        |    |
|     | %                             | 4    | 4  | 5  | 3        | 1   | 2   |           |        |    |

Average  $\Delta$ /s by Lab

| Lab      | n   | AGVYI |
|----------|-----|-------|
| A        | 66  | 0.557 |
| B        | 34  | 0.719 |
| D        | 7   | 0.972 |
| G        | 46  | 0.192 |
| Industry | 153 | 0.502 |

Individual test results can be found on the TMC Web Page at the following link:

<ftp://ftp.astmtmc.cmu.edu/refdata/bench/brt/data/>


CUSUM PLOT

**BALL RUST TEST INDUSTRY OPERATIONALLY VALID DATA**




**REFERENCE AVERAGE GRAY VALUE**

CUSUM Severity Analysis



POOLED S:

Pooled s for this period is 8.19. Shown below is a bar chart comparing the pooled s values for AGV over the last four report periods.



STATUS OF REFERENCE OIL SUPPLY:

At the end of this report period, the testing oil supply stood as outlined in the following table:

| Oil   | Samples @ Labs | @ TMC           |         |
|-------|----------------|-----------------|---------|
|       |                | Samples (30 mL) | Gallons |
| 1006  | 51             | 4887            | 39.1    |
| 81    | 60             | 1550            | 12.4    |
| 82    | 41             | 812             | 6.5     |
| 82-1  | 8              | 1225            | 9.8     |
| Total | 97             | 8474            | 67.8    |

INFORMATION LETTERS:

No information letters were issued this period.

SUMMARY

- Over the course of this report period, AGV severity as measured by cusum plotting continued the mild trend that has existed since the inception of the test.
- Precision as measured by pooled standard deviation is better than previous periods.

MTK/mtk/astm1010.doc/mem10-054.mtk.doc

c: F. M. Farber

J. A. Clark

BRT Surveillance Panel

<ftp://ftp.astmtmc.cmu.edu/docs/bench/brt/semiannualreports/brt-10-2010.pdf>

Distribution: email