



Test Monitoring Center

@ Carnegie Mellon University
6555 Penn Avenue, Pittsburgh, PA 15206, USA

<http://astmtmc.cmu.edu>
412-365-1000

MEMORANDUM: 14-037

DATE: November 19, 2014

TO: Yong-Li McFarland,
Chairwoman, Engine Oil Filterability Test Surveillance Panel

FROM: Michael T. Kasimirsky *Michael T. Kasimirsky*

SUBJECT: EOWT Testing from April 1, 2014 through September 30, 2014

A total of 1,039 EOWT tests were reported to the Test Monitoring Center during the report period from April 1, 2014 through September 30, 2014.

Please find attached a summary of testing activity this period.

MTK/mtk/astm1014.doc/mem14-037.mtk.doc

cc: F. M. Farber

J. A. Clark

EOWT Surveillance Panel


<ftp://ftp.astmtmc.cmu.edu/docs/bench/eowt/semiannualreports/eowt-10-2014.pdf>

Distribution: email

EOWT (D 6794)

Reporting Data	
Number of Labs	4

NUMBER OF TESTS REPORTED
BY LAB AND REPORT PERIOD



11:13:48 15NOV2014


EOWT (D 6794)

Test Distribution by Oil and Validity

		By Oil				By Treat Level				Totals	
		77-1	77-2	78-1	78-2	0.6	1.0	2.0	3.0	This Period	Last Period
Accepted for Calibration	AC	4	596	0	398	251	249	250	248	998	758
Acceptable Donated Tests	NI	0	0	0	0	0	0	0	0	0	0
Unacceptable Donated Tests	MI	0	0	0	0	0	0	0	0	0	0
Rejected Tests	OC	0	6	0	1	1	4	1	1	7	6
Operationally Invalid (lab)	LC	0	5	0	3	2	2	2	2	8	2
Operationally Invalid (lab/TMC)	RC	0	0	0	0	0	0	0	0	0	0
Aborted Calibration	XC	0	24	0	2	6	6	7	7	26	33
Total		4	631	0	404	260	261	260	258	1039	799

EOWT (D 6794)

CALIBRATION ATTEMPT SUMMARY




Resolution

Report Period

11:13:48 19NOV2014

EOWT (D 6794)

OPERATIONALLY VALID TESTS
MEETING ACCEPTANCE CRITERIA



11:13:48 19NOV2014

EOWT (D 6794)

CAUSES FOR LOST TESTS

		Oil				Validity			Loss Rate		
Lab	Cause	77-1	77-2	78-1	78-2	LC	RC	XC	Lost	Starts	%
A	Blender failure	0	2	0	2	0	0	4	4	376	1%
B	Sample Prep Error	0	20	0	3	7	0	16	23	446	5%
	Sample Lost	0	1	0	0	1	0	0	1		0.2%
G	Power Failure	0	4	0	0	0	0	4	4	148	3%
I	Burette Broken	0	2	0	0	0	0	2	2	69	3%
	Lost	0	29	0	5	8	0	26			
	Starts	4	631	0	404	1039	1039	1039			
	%	0%	5%	0%	1%	1%	0%	3%			

1

Lost tests are calibration attempts that were either aborted or operationally invalid

EOWT (D 6794)

Average Δ /s By Laboratory			
Treat Level	Lab	n	CFAYI
0.6	A	94	-0.408
	B	106	0.408
	G	36	0.825
	I	16	1.288
	Industry	252	0.219
1.0	A	92	-0.176
	B	106	0.137
	G	36	0.685
	I	19	1.273
	Industry	253	0.187
2.0	A	93	-0.286
	B	106	0.279
	G	36	0.740
	I	16	1.065
	Industry	251	0.186
3.0	A	93	0.049
	B	104	0.409
	G	36	0.631
	I	16	1.243
	Industry	249	0.360


EOWT (D 6794)

Individual test results can be found on the TMC Web Page at the following link:

<ftp://ftp.astmtmc.cmu.edu/refdata/bench/eowt/data/>

EOWT (D 6794)

AVERAGE DELTA/S



11:13:48 19NOV2014


EOWT (D 6794)

EOWT INDUSTRY OPERATIONALLY VALID DATA



20 — 25 ML CHANGE IN FLOWRATE AVG.

CUSUM Severity Analysis




19NOV14:11:09



EOWT (D 6794)

POOLED STANDARD DEVIATION



11:13:48 19NOV2014

EOWT (D 6794)

SUMMARY OF SEVERITY & PRECISION

Severity

Over the course of this report period, CIFA severity, as measured by CUSUM plotting, is trending slightly severe.

Precision

Pooled s values for this period are 4.02 (0.6%), 3.43 (1.0%), 4.51 (2.0%), and 3.66 (3.0%).

Precision, as measured by pooled standard deviation, is still comparable to historical performance.

EOWT (D 6794)

INFORMATION LETTERS

No EOWT Information Letters were issued this period.

EOWT (D 6794)

STATUS OF REFERENCE OIL SUPPLY

Oil	Samples @ Labs	@ TMC	
		Samples (290 mL)	Gallons
77-1	0	0	0.0
77-2	112	1,909	147.0
78-1	0	0	0.0
78-2	156	261	20.1
79	0	13,584	1,046.0
Total	268	15,754	1,213.1

The TMC inventories of oils 77-1 & 78-1 are depleted.

The TMC inventory of oil 78-2 is nearly depleted.

The TMC has procured a reblend of oil 78-2, called reference oil 79.

Plans to introduce reference oil 79 into EOFT testing are ongoing.