

Test Monitoring Center

@ Carnegie Mellon University 6555 Penn Avenue, Pittsburgh, PA 15206, USA

http://astmtmc.cmu.edu 412-365-1000

MEMORANDUM: 16-040

DATE: November 7, 2016

TO: Yong-Li McFarland,

Chairwoman, Engine Oil Filterability Test Surveillance Panel

FROM: Michael T. Kasimirsky Michael J. Kasimirsky

SUBJECT: EOWT Testing from April 1, 2016 through September 30, 2016

A total of 958 EOWT tests were reported to the Test Monitoring Center during the report period from April 1, 2016 through September 30, 2016.

Please find attached a summary of testing activity this period.

MTK/mtk/astm1016.doc/mem16-040.mtk.doc

cc: F. M. Farber J. A. Clark


EOWT Surveillance Panel

ftp://ftp.astmtmc.cmu.edu/docs/bench/eowt/semiannualreports/eowt-10-2016.pdf

Distribution: email

	Reporting Data
Number of Labs	5

NUMBER OF TESTS REPORTED BY LAB AND REPORT PERIOD








Test Distribution by Oil and Validity

		By Oil			By Treat Level				Totals		
		77-2	77-3	78-2	79	0.6	1.0	2.0	3.0	This Period	Last Period
Accepted for Calibration	AC	464	0	6	447	230	230	230	227	917	765
Rejected Tests	ОС	5	0	0	0	1	0	0	4	5	10
Operationally Invalid (lab)	LC	1	0	0	2	2	1	0	0	3	1
Operationally Invalid (lab/TMC)	RC	0	0	0	0	0	0	0	0	0	0
Aborted Calibration	XC	15	0	0	6	5	6	5	5	21	12
Unusable Calibration	МС	0	0	0	0	0	0	0	0	0	0
Acceptable Donated Tests	NI	0	12	0	0	3	3	3	3	12	8
Unacceptable Donated Tests	MI	0	0	0	0	0	0	0	0	0	0
Invalid Donated Tests	LI	0	0	0	0	0	0	0	0	0	0
Aborted Donated Tests	ΧI	0	0	0	0	0	0	0	0	0	0
Total	1	485	12	6	455	241	240	238	239	958	796




CALIBRATION ATTEMPT SUMMARY







OPERATIONALLY VALID TESTS MEETING ACCEPTANCE CRITERIA







CAUSES FOR LOST TESTS

			Oil			Validity			Loss Rate			
Lab	Cause		77-2	77-3	78-2	79	LC	RC/ MC	XC	Lost	Starts	%
Α	Sample P	rep Error	4	0	0	1	2	0	3	5	337	1.5
В	Sample P	rep Error	8	0	0	0	0	0	8	8	300	2.7
Ь	Computer	r Failure	0	0	0	6	0	0	6	6	300	2.0
G	Sample P	rep Error	4	0	0	1	1	0	4	5	272	1.8
	1	Lost	16	0	0	8	3	0	21			
		Starts	485	12	6	455	958	958	958			
		%	3.3	0	0	1.8	0.3	0	2.2			

Lost tests are calibration attempts that were either aborted or operationally invalid





Average Δ/s By Laboratory						
Treat Level	Lab	n	CFAYI			
0.6	Α	84	-0.023			
	В	69	1.024			
	G	67	1.065			
	I	9	0.173			
	L	2	0.314			
	Industry	231	0.616			
1.0	Α	82	-0.165			
	В	69	0.828			
	G	67	1.114			
	I	10	0.727			
	L	2	-0.074			
	Industry	230	0.545			
2.0	Α	82	0.202			
	В	70	0.882			
	G	67	0.980			
	I	9	0.406			
	L	2	-0.406			
	Industry	230	0.638			
3.0	Α	84	0.202			
	В	70	1.108			
	G	66	1.177			
	I	9	0.986			
	L	2	0.183			
	Industry	231	0.786			


Individual test results can be found on the TMC Web Page at the following link:

ftp://ftp.astmtmc.cmu.edu/refdata/bench/eowt/data/





AVERAGE DELTA/S








EOWT INDUSTRY OPERATIONALLY VALID DATA



20 - 25 ML CHANGE IN FLOWRATE AVG.


CUSUM Severity Analysis







POOLED STANDARD DEVIATION







EOWT (D 6794)SUMMARY OF SEVERITY & PRECISION

Severity

Over the course of this report period, CIFA severity, as measured by CUSUM plotting, is severe.

Precision

Pooled s values for this period are 3.47 (0.6%), 3.66 (1.0%), 3.21 (2.0%), and 3.54 (3.0%).

Precision, as measured by pooled standard deviation, is better than previous periods, but still comparable to historical performance.





INFORMATION LETTERS

No EOWT Information Letters were issued this period.



STATUS OF REFERENCE OIL SUPPLY

		@ TMC				
Oil	Samples @ Labs	Samples (290 mL)	Gallons			
77-2	123	248	19.1			
77-3	63	11,572	891.1			
78-2	0	0	0.0			
79	129	11,135	857.4			
Total	315	22,955	1,767.6			

The TMC inventory of oil 77-2 is nearly depleted.

The TMC has procured a reblend of oil 77-2, reference oil 77-3, which has been introduced into EOWT.

Testing on reference oil 77-3 will begin when the current inventory of reference oil 77-2 is depleted.



