



A Program of ASTM International

Test Monitoring Center

@ Carnegie Mellon University
6555 Penn Avenue, Pittsburgh, PA 15206, USA

<http://astmtmc.cmu.edu>
412-365-1000

MEMORANDUM: 16-009

DATE: April 28, 2016

TO: Brad Bubonic, Chairman, L-60-1 Surveillance Panel

FROM: Scott Parke

A handwritten signature in blue ink that appears to read "S. Parke".

SUBJECT: L-60-1 Reference Oil Testing from October 1, 2015 through March 31, 2016

Please find attached a summary of testing activity this period.

SDP/sdp/mem16-009.sdp.doc

cc: Frank Farber

Jeff Clark

L-60-1 Surveillance Panel


<ftp://ftp.astmtmc.cmu.edu/docs/gear/l601/semiannualreports/l601-04-2016.pdf>

Distribution: email

L-60-1 (D5704)

| | Reporting Data | Calibrated on 3-31-16 |
|------------------|----------------|-----------------------|
| Number of Labs | 4 | 4 |
| Number of Stands | 9 | 8 |

BY-LAB STAND DISTRIBUTION



13:16:39 27APR2016


L-60-1 (D5704)

Test Distribution by Oil and Validity

| | | 148-1 | 151-2 | 155-1 | Totals | |
|--------------------------|----|-------|-------|-------|-------------|-------------|
| | | | | | Last Period | This Period |
| Accepted for calibration | AC | 12 | 3 | 5 | 22 | 20 |
| Rejected (Mild) | OC | 0 | 0 | 0 | 1 | 0 |
| Rejected (Severe) | OC | 0 | 1 | 0 | 14 | 1 |
| Rejected (Precision) | OC | 1 | 0 | 2 | 2 | 3 |
| Invalidated calibration | LC | 0 | 0 | 0 | 0 | 0 |
| Acceptable info run | NI | 0 | 1 | 0 | 0 | 1 |
| Unacceptable info run | MI | 0 | 0 | 0 | 0 | 0 |
| Operationally invalid | RC | 0 | 0 | 0 | 0 | 0 |
| Aborted | XC | 1 | 0 | 0 | 1 | 1 |
| Total | | 14 | 5 | 7 | 40 | 26 |

L-60-1 (D5704)


CALIBRATION ATTEMPT SUMMARY



13:16:39 27APR2016

L-60-1 (D5704)

OPERATIONALLY VALID TESTS MEETING ACCEPTANCE CRITERIA




13:16:39 27APR2016


L-60-1 (D5704)

CAUSES FOR FAILED TESTS

By Alarm Type



By Parameter



L-60-1 (D5704)

CAUSES FOR LOST TESTS

| Lab | Cause | Oil | | | Validity | | | Loss Rate | | |
|-----|-----------------------------|-------|-------|-------|----------|----|----|-----------|--------|----|
| | | 148-1 | 151-2 | 155-1 | RC | LC | XC | Lost | Starts | % |
| A | Aborted @34hrs for oil leak | ● | | | | | ● | 1 | 13 | 8% |
| | Lost | 1 | 0 | 0 | 0 | 0 | 1 | | | |
| | Starts | 14 | 5 | 7 | 26 | 26 | 26 | | | |
| | % | 7% | 0% | 0% | 0% | 0% | 4% | | | |

L-60-1 (D5704)


| Average Δ/s by Lab | | | | | | |
|--------------------|----|--------|--------|--------|--------|--------|
| Lab | n | VISI | PEN | TOL | ACV | ASL |
| A | 12 | 0.878 | 0.066 | -0.126 | -0.031 | 0.109 |
| B | 4 | 0.440 | 2.102 | 2.295 | -3.232 | -0.811 |
| D | 7 | -0.099 | 0.690 | 1.377 | -0.062 | -0.032 |
| G | 1 | -0.026 | -0.958 | -0.835 | -0.195 | -0.774 |
| Industry | 24 | 0.482 | 0.545 | 0.686 | -0.580 | -0.122 |
| Shift* | 24 | 3.694 | 0.225 | 0.171 | -0.296 | -0.013 |

*computed using severity adjustment standard deviation. A correction factor was implemented for ACV on October 1, 2015 that is intended to return industry ACV performance to the level originally seen in the test.

L-60-1 (D5704)

TEST SEVERITY

DELTA/S BY LAB




13:16:39 27APR2016

L-60-1 (D5704)

TEST PRECISION

POOLED STANDARD DEVIATION
BY SIX-MONTH ASTM REPORT PERIOD



due to the vastly larger reported results for VISI in relation to the other parameters, it is shown scaled by 0.1

13:16:39 27APR2016

L-60-1 (D5704)

SUMMARY OF SEVERITY & PRECISION

Severity

The Surveillance Panel enacted a correction factor for ACV on October 1, 2015 intended to return ACV to target. Severe ACV results at lab B since then have kept the chart in alarm. Severe PEN and TOL results from lab B have also kept those charts in alarm. ASL and VISI remained within limits this period.

Precision


The severe ACV results from lab B have generated precision alarms this period. Precision for all other parameters continues to be good.

Industry control charts follow.

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA


REF. FINAL AVERAGE CARBON/ VARNISH



L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA


REF. FINAL AVERAGE SLUDGE



L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL PENTANE INSOLUBLES



Sopra

Test Monitoring Center


<http://astmtmc.cmu.edu>



L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA


REF. FINAL TOLUENE INSOLUBLES



L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL VISCOSITY INCREASE




L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE CARBON/ VARNISH

LTMS Precision Analysis



COUNT IN COMPLETION DATE ORDER


27APR16:15:28

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE SLUDGE

LTMS Precision Analysis




27APR16:15:28

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL PENTANE INSOLUBLES

LTMS Precision Analysis



COUNT IN COMPLETION DATE ORDER


27APR16:15:27

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL TOLUENE INSOLUBLES

LTMS Precision Analysis




27APR16:15:27

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL VISCOSITY INCREASE




27APR16:15:27

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE CARBON/ VARNISH

CUSUM Severity Analysis



27APR16:15:30

Test Monitoring Center
<http://astmtmc.cmu.edu>




A Program of ASTM International

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE SLUDGE

CUSUM Severity Analysis




27APR16:15:30

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL PENTANE INSOLUBLES

CUSUM Severity Analysis




27APR16:15:30

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL TOLUENE INSOLUBLES

CUSUM Severity Analysis




27APR16:15:30

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL VISCOSITY INCREASE

CUSUM Severity Analysis



27APR16:15:30

L-60-1 (D5704)

TIMELINE ADDITIONS

| Effective Date | Information Letter | Event |
|----------------|--------------------|--|
| 20151029 | 15-4 | Discontinue transformation of test results |
| 20151029 | 15-4 | Implementation of ACV correction factor |

L-60-1 (D5704)

LAB VISITS

No L-60-1 lab visits were conducted this period.

INFORMATION LETTERS

Information Letter 15-4 was issued on October 29, 2015 to discontinue the transformation of test results and to implement an ACV correction factor.

L-60-1 (D5704)

STATUS OF REFERENCE OIL SUPPLY

| Oil | Cans @ Labs | @ TMC | |
|-------|-------------|-------|---------|
| | | Cans | Gallons |
| 148-1 | 23 | 448 | 28.1 |
| 151-2 | 1 | 0 | 0.0 |
| 155-1 | 24 | 635 | 39.7 |
| Total | 48 | 1083 | 67.8 |

A reblend of 151-2 (151-3) was acquired by TMC in 1999 but has since been consumed in other test types. That oil was then replaced by 155 which is also now depleted. A 155 reblend (155-1) is on hand at TMC. The surveillance panel has asked that the TMC reserve a portion of that oil for L-60-1 testing. The TMC quantity shown for this oil is for that reserved portion. A separate quantity of 231 gallons is available for use in other gear testing.

Four hundred and forty eight tests of oil 148-1 remain in TMC inventory; however, this is only 28 gallons. When the need arises, it will not be possible to obtain a reblend of this oil. The panel is advised to begin considering a possible replacement for this oil.