



Test Monitoring Center


@ Carnegie Mellon University
6555 Penn Avenue, Pittsburgh, PA 15206, USA

<http://astmtmc.cmu.edu>
412-365-1000

MEMORANDUM: 16-044

DATE: November 21, 2016

TO: Brad Bubonic, Chairman, L-60-1 Surveillance Panel

FROM: Scott Parke 

SUBJECT: L-60-1 Reference Oil Testing from April 1, 2016 through September 30, 2016

Attached is a summary of testing activity this period.

SDP/sdp/mem16-044.sdp.doc

cc: Frank Farber

Jeff Clark

L-60-1 Surveillance Panel


<ftp://ftp.astmtmc.cmu.edu/docs/gear/l601/semiannualreports/l601-10-2016.pdf>

Distribution: email

L-60-1 (D5704)

	Reporting Data	Calibrated on 9-30-16
Number of Labs	4	4
Number of Stands	10	9

BY-LAB STAND
DISTRIBUTION



10:05:36 14NOV2016


L-60-1 (D5704)

Test Distribution by Oil and Validity

					Totals	
		148-1	151-2	155-1	Last Period	This Period
Accepted for calibration	AC	8	0	9	20	17
Rejected (Mild)	OC	0	0	0	0	0
Rejected (Severe)	OC	1	0	5	1	6
Rejected (Combination)	OC	0	1	0	0	1
Rejected (Precision)	OC	1	0	0	3	1
Invalidated calibration	LC	1	0	1	0	2
Acceptable info run	NI	0	0	10	1	10
Unacceptable info run	MI	0	0	1	0	1
Aborted	XC	2	0	0	1	2
Total		13	1	26	26	40

L-60-1 (D5704)


CALIBRATION ATTEMPT SUMMARY



10:05:36 14NOV2016

L-60-1 (D5704)

OPERATIONALLY VALID TESTS
MEETING ACCEPTANCE CRITERIA




10:05:36 14NOV2016


L-60-1 (D5704)

CAUSES FOR FAILED TESTS

By Alarm Type



By Parameter



L-60-1 (D5704)

CAUSES FOR LOST TESTS

		Oil			Validity			Loss Rate		
Lab	Cause	148-1	151-2	155-1	MI	LC	XC	Lost	Starts	%
A	Excess oil loss at EOT	●				●		3	16	19%
	Abort at 9h due to loose drive belt	●					●			
	Oil leak at 33h	●					●			
B	Excess oil loss (shakedown run)			●	●			1	12	8%
G	Low air pressure			●		●		1	6	17%
Lost		3	0	2	1	2	2			
Starts		13	1	26	40	40	40			
%		23%	0%	8%	3%	5%	5%			

L-60-1 (D5704)


Average Δ /s by Lab						
Lab	n	VISI	PEN	TOL	ACV	ASL
A	13	1.067	-0.225	-0.203	-0.586	0.044
B	1	0.527	0.031	0.574	-1.577	-0.302
D	6	0.349	0.703	1.108	-0.806	0.007
G	5	-1.097	0.465	0.494	0.297	-1.568
Industry	25	0.440	0.146	0.282	-0.502	-0.301
Shift*	25	3.371%	0.060%	0.070%	-0.256 merit	-0.032 merit

*computed using severity adjustment standard deviation. A correction factor was implemented for ACV on October 1, 2015 that is intended to return industry ACV performance to the level originally seen in the test.

L-60-1 (D5704)

TEST SEVERITY

DELTA/S BY LAB




10:05:36 14NOV2016

L-60-1 (D5704)

TEST PRECISION

POOLED STANDARD DEVIATION
BY SIX-MONTH ASTM REPORT PERIOD



due to the vastly larger reported results for VISI in relation to the other parameters, it is shown scaled by 0.1

10:05:36 14NOV2016

L-60-1 (D5704)

SUMMARY OF SEVERITY & PRECISION

Severity

The Surveillance Panel enacted a correction factor for ACV on October 1, 2015 intended to return ACV to target. This correction has improved ACV severity, however the industry chart is currently exceeding the warning alarm limit. A string of 3 severe VISI results from lab A put that chart over the alarm limit for a time but it has since recovered. ASL, PEN, and TOL all showed acceptable control this period.

Precision

Precision for all parameters remained within limits this period.


Industry control charts follow.

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE CARBON/ VARNISH

LTMS Severity Analysis



SPVERP


14NOV16: 10:24

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE SLUDGE

LTMS Severity Analysis



SPVERP


14NOV16: 10:24

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL PENTANE INSOLUBLES

LTMS Severity Analysis



SPVERP


14NOV16: 10:23

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL TOLUENE INSOLUBLES

LTMS Severity Analysis



SPVERP


14NOV16: 10:24

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL VISCOSITY INCREASE

LTMS Severity Analysis



SPVERP


14NOV16: 10:23

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE CARBON/ VARNISH

LTMS Precision Analysis



14NOV16: 10:26

Test Monitoring Center
<http://astmtmc.cmu.edu>




L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE SLUDGE

LTMS Precision Analysis




14NOV16: 10:26

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL PENTANE INSOLUBLES

LTMS Precision Analysis




14NOV16: 10:26

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL TOLUENE INSOLUBLES

LTMS Precision Analysis




14NOV16: 10:26

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL VISCOSITY INCREASE

LTMS Precision Analysis




14NOV16: 10:26

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE CARBON/ VARNISH

CUSUM Severity Analysis




14NOV16: 10:29

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL AVERAGE SLUDGE

CUSUM Severity Analysis




14NOV16: 10:29

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL PENTANE INSOLUBLES

CUSUM Severity Analysis




14NOV16: 10:29

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL TOLUENE INSOLUBLES

CUSUM Severity Analysis




14NOV16: 10:29

L-60-1 (D5704)

L-60-1 INDUSTRY OPERATIONALLY VALID DATA

REF. FINAL VISCOSITY INCREASE

CUSUM Severity Analysis



14NOV16: 10:29

L-60-1 (D5704)

TIMELINE ADDITIONS

Effective Date	Information Letter	Event
20160526	16-1	Clarification of how corrected test results are to be reported.

L-60-1 (D5704)

LAB VISITS

One L-60-1 lab visit was conducted this period. No procedural nonconformances were found.

INFORMATION LETTERS

Information Letter 16-1 was issued on May 26, 2016 to clarify how to handle test results where a correction factor causes the result to exceed the upper or lower range of the measurement scale.

L-60-1 (D5704)

STATUS OF REFERENCE OIL SUPPLY

Oil	Cans @ Labs	@ TMC	
		Cans	Gallons
148-1	20	435	27.2
151-2	0	0	0.0
155-1	22	624	39.0
Total	42	1059	66.2

A reblend of 151-2 (151-3) was acquired by TMC in 1999 but has since been consumed in other test types. That oil was then replaced by 155 which is also now depleted. A 155 reblend (155-1) is on hand at TMC. The surveillance panel has asked that the TMC reserve a portion of that oil for L-60-1 testing. The TMC quantity shown for this oil is for that reserved portion. A separate quantity of 197 gallons is available for use in other gear testing.

Four hundred and thirty five tests of oil 148-1 remain in TMC inventory; however, this is only 27 gallons. When the need arises, it will not be possible to obtain a reblend of this oil. The panel is advised to begin considering a possible replacement for this oil.