

SOUTHWEST RESEARCH INSTITUTE
 6220 CULEBRA ROAD
 P.O. DRAWER 28510
 78238, SAN ANTONIO
 United States



Attention of : Mr. D. Engstrom
 Your reference : P.O. P40352CE

Analysis Report

Report number : 13072/00012442.1/L/21 Submitted date : 10-12-2021
 Sample submitted at : Saybolt LP, Deer Park
 Report Date : 10-19-2021 Date received : 10-12-2021
 Date of issue : 10-19-2021 Date completed : 10-19-2021
 Sample object : Southwest Research Institute Sample number : 12256055
 Sample type : Submitted
 Sample submitted as : Gasoline
 Marked : Haltermann Gasoline-Medium RVP

NAME	METHOD	UNIT	RESULT
API Gravity	ASTM D 4052	°API	58.6
Distillation	ASTM D 86		
Initial boiling point		°F	87.9
5% Evaporated		°F	111.3
10% Evaporated		°F	125.2
20% Evaporated		°F	144.8
30% Evaporated		°F	167.2
40% Evaporated		°F	195.8
50% Evaporated		°F	219.9
60% Evaporated		°F	232.6
70% Evaporated		°F	243.5
80% Evaporated		°F	262.1
90% Evaporated		°F	315.9
95% Evaporated		°F	339.4
Final boiling point		°F	390.1
Recovery		vol %	97.3
Residue		vol %	1.1
Loss		vol %	1.6
Evaporated at 200 °F		vol %	41.5
Evaporated at 300 °F		vol %	87.6
Heat Of Combustion, Net	ASTM D 3338	Btu/lb	18452
Hydrocarbon Type FIA	ASTM D 1319		
Aromatics		vol %	28.7
Olefins		vol %	0.7
Saturates		vol %	70.6
Sulfur	ASTM D 5453	mg/kg	2.8
Vapor Pressure	ASTM D 5191		

All results in this report refer to the sample(s) tested as taken or submitted like specified in this Analysis report. Uncertainties, available on request, apply in the evaluation of the test results. All tests are conducted according to the latest version of the methods, unless another version is specifically indicated. Where available and for convenience purposes, the tested sample has been checked for compliance with supplied specifications, without accepting any liability. In case of dispute or concern, we refer to the interpretation of test results as defined in ASTM D3244, IP 367, ISO 4259 or GOST 33701. This report shall not be partially copied and reproduced without the written permission of the laboratory.

SOUTHWEST RESEARCH INSTITUTE
6220 CULEBRA ROAD
P.O. DRAWER 28510
78238, SAN ANTONIO
United States



Attention of : Mr. D. Engstrom
Your reference : P.O. P40352CE

Analysis Report

Report number : **13072/00012442.1/L/21** Submitted date : 10-12-2021
Sample submitted at : Saybolt LP, Deer Park
Report Date : 10-19-2021 Date received : 10-12-2021
Date of issue : 10-19-2021 Date completed : 10-19-2021
Sample object : Southwest Research Institute Sample number : 12256055
Sample type : Submitted
Sample submitted as : Gasoline
Marked : Haltermann Gasoline-Medium RVP

NAME	METHOD	UNIT	RESULT
Vapor Pressure, EPA Eq.		psi@100F	8.46
Vapor Pressure, ASTM Eq.		psi@100F	8.34

Signed by: Sandra Kaluza - Laboratory Coordinator
Issued by: Saybolt LP
Place and date of issue: Deer Park - 10-19-2021

All results in this report refer to the sample(s) tested as taken or submitted like specified in this Analysis report. Uncertainties, available on request, apply in the evaluation of the test results. All tests are conducted according to the latest version of the methods, unless another version is specifically indicated. Where available and for convenience purposes, the tested sample has been checked for compliance with supplied specifications, without accepting any liability. In case of dispute or concern, we refer to the interpretation of test results as defined in ASTM D3244, IP 367, ISO 4259 or GOST 33701. This report shall not be partially copied and reproduced without the written permission of the laboratory.